### **Autonics**

# TEMPERATURE CONTROLLER T3H/T3HA/T3HS SERIES



Thank you very much for selecting Autonics products. For your safety, please read the following before using.

### Caution for your safety

\*Please keep these instructions and review them before using this unit.

\*Please observe the cautions that follow;

Marning Serious injury may result if instructions are not followed.

**↑** Caution Product may be damaged, or injury may result if instructions are not followed.

\*The following is an explanation of the symbols used in the operation manual. Acaution:Injury or danger may occur under special conditions.

#### /\ Warning

- 1. In case of using this unit with machineries(Nuclear power control, medical equipment, vehicle, train, airplane, combustion apparatus, entertainment of safety device etc), it requires installing fail-safe device, or contact us for information on type required.
- It may result in serious damage, fire or human injury

  2. This unit must be mounted on panel.
- 3. Do not repair or checkup when power on.
- 4. Do not disassemble and modify this unit, when it requires.
- If needs, please contact us.
- 5. This product is a combined use of 110/220VAC, please check the terminal when connect

#### **⚠** Caution


- 1. This unit shall not be used outdoors.
- It might shorten the life cycle of the product or give an electric shock.

  2. When wire connection, No.20AWG(0.50mm²) should be used and screw bolt
- on terminal block with 0.74N  $\cdot$  m to 0.90N  $\cdot$  m strength. ue to contact failure
- 3. Please observe specification rating.
- 4. Do not use the load beyond rated switching capacity of Relay contact. It may cause insulation failure, contact melt, contact failure, relay broken, fire etc
- 5. In cleaning the unit, do not use water or an oil-based detergent.
- might cause an electric shock or fire that will result in damage to this produc 6. Do not use this unit at place where there are flammable or explosive gas, humidity. direct ray of the sun, radiant heat, vibration, impact etc.
- It may cause a fire or explosion.

  7. Do not inflow dust or wire dregs into inside of this unit.
- 8. Please wire properly after checking the polarity of terminals when connect
- It may cause a fire or explosion

### Dimensions ●Panel cut-out 146 124 399 Min. 112 45.5 +0


### Ordering information




### Specifications

INIOGOI		1011	1011/1	10110			
Power s	upply		110/220VAC 50/60Hz				
Allowable voltage range		90 to 110% of rated voltage					
Power c	onsumption	3VA					
Display	method	7 Segment LED Display					
Display	accuracy	F • S ±0.5% rdg ±1digit□					
Setting method		Digital setting					
Setting accuracy		F • S ±0.5%					
Sensor input		Thermocouples:K(CA), J(IC) / RTD:Pt100Ω					
Input lin	e resistance	Thermocouples:Max. 100Ω, RTD:Max. 5Ω per a wire					
	ON/OFF	Hysteresis: F • S 0.5 to 3% variable□					
	Proportional	Proportional band: F • S 1 to 10% variable, Period: 20sec fixed					
Control	SUB	0 to -50°C variable					
	Alarm	F • S 0 to 10% variable					
Reset VI	R range	F • S ±3% variable(Correct of control deviation)					
Control	output	<ul> <li>SSR output:24VDC ±3V 20mA max.</li> <li>Current output:4-20mADC(Load 600Ω max.)</li> <li>T3HA:Alarm contact output:250VAC 1A 1a</li> <li>T3HS:Double contact output:250VAC 1A 1a</li> </ul>					
Self-diagnosis		Built-in burn out function					
Insulation resistance		Min. 100MΩ(at 500VDC)					
Dielectri	c strength	2000VAC 50/60Hz for 1 minute					
Noise strength		$\pm 2 \text{kV}$ the square wave noise(pulse width:1 $\mu\text{s})$ by the noise simulator					
Vibra	Mechanical	0.75mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 1 hour					
-tion	Malfunction	0.5mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 10 minutes					
01	Mechanical	300m/s² (Approx. 30G) 3 times at X, Y, Z direction					
Shock	Malfunction	100m/s² (Approx. 10G) 3 times at X, Y, Z direction					
Relay	Mechanical	Min.10,000,000 times					
life cycle Electrical		Min.100,000 times(250VAC 3A resistive load)					
Ambient temperature		-10 to 50℃ (at non-freezing status)					
Storage temperature		-25 to 65℃ (at non-freezing status)□					
Ambient	humidity		35 to 85%RH				
Weight		Approx. 496g	Approx. 514g	Approx. 517g			

### Connections



\*The above specification are changeable without notice anytime




### Temperature range for each sensor

Model T3H				ТЗНА					T3HS					
Sensor input type		The	Thermocouples		RTD		Thermocouples		RTD	Thermocouples		RTD		
		J(IC)	K(CA)		Pt100Ω		J(IC) K(CA)		Pt100Ω	J(IC)	K(CA) Pt100	Pt100Ω		
Standard scale range(°C)	1600° 1200 1000 800 600 400 200													
			999°C						999	°C		1		
			799°	Ö				79	9℃					
					ļ									
		399℃	399℃			399℃	399℃	399℃			399.℃	.399°C.	399.℃	399℃
					19	9℃					.199.℃			
	100				99.9℃									
	0													
	-100					<b>.</b>								
					-9	9℃					-99℃			

#### ON/OFF control

The drawing shows that the output turns on when the temperature is lower than the set value. (Heater ON) The output turns off when temperature is equal or higher than the set value. (Heater OFF)




As like above picture, the control value is up and down by set value, it is called Hunting And Overshoot is occurred at initial point when just power on

If the Hunting and Overshoot is less, it will be a good control.


### Hvsteresis

The ON/OFF control has hysteresis due to reduce the chattering or noise affection. Generally make hysteresis bigger of compressor for cooler due to this reason.



Ex)If temperature range is 0 to 400°C and hysteresis is  $0.5\%(2^{\circ}C)$ , therefore when the set value is 300°C. 301°C:OFF and 299°C:ON

## Proportional control



\*If the temperature is getting higher, ON time will be shorter.

Pulse output type of ON/OFF such as Relay output or SSR output (Voltage output) are ON/OFF repeatedly with constant cycle. When the PV and SV is the same, the output value will be 50% and ON/OFF time rate is 1:1

## How to select ON/OFF or proportional by plug pin

Control mode selection by plug pin




\* P : Proportional control




#### Function

- ●BURN OUT detection function:
- Make the output OFF when the thermocouple is broken.
- Voltage output
- The output is 24VDC  $\pm$ 3V 20mA max for driving external SSR.
- •Direct/Reverse operation: Reverse operation is the output ON when the display value is lower than set value, Direct operation is for cooler. \*This product operates as reverse operation.

#### Load connection





### Applications

Food	Packaging machinery, Banding machinery
Plastic	Plastic machinery, Film making system, etc.
Industry	Electric furnace, Auto soldering machine, Drying machine, etc.
Textile□	Body press, Textile machine, Sizing machine
Etc.□	Cement making machinery

#### Caution for using

- 1. Installation environmen
- (1) It shall be used indoor
- ②Altitude Max 2000m
- ③Pollution Degree 2 (4)Installation Category II
- 2. Please use the terminal(M3.5, Max.7.2mm) when
- connect the AC power source. 3. Please use separated line from high voltage line or power line in order to
- avoid inductive noise 4. Please install power switch or circuit-breaker in order to cut power supply
- 5. The switch or circuit-breaker should be installed near by users.
- 6. Do not use this product as Volt-meter or Ampere-meter, this is a temperature controller.
- 7. Be sure to use compensating wire when extends wire from controller. otherwise the temperature deviation will be occurred at the part where wires are connected each other. 8. In case of using RTD sensor, 3wire type must be used.
- If it needs to extend the line, 3wires must be used with the same thickness as the line. It might cause the deviation of temperature if the resistance of line is different.
- 9. In case of making power line and input signal line close, line filter for noise protection should be installed at power line and input signal line should be shielded.
- 10. Keep away from the high frequency instruments. (High frequency welding machine & sewing machine, big capacitive SCR controller)
- 11. Do not connect power line on No.15, 16, 17 of terminal block for the

\*It may cause malfunction if above instructions are not followed.

## Main products

- COUNTER
- TEMPERATURE CONTROLLER
   PANEL METER
- TACHOMETER/ LINE SPEED METER/ PULSE METER
- DISPLAY UNIT PROXIMITY SENSOR
- PHOTOFI FCTRIC SENSOR
- IBER OPTIC SENSOR RESSURE SENSOR
- ROTARY ENCODER
   SENSOR CONTROLLER
   POWER CONTROLLER
- STEPPING MOTOR & DRIVER & CONTROLLER

### Autonics Corporation http://www.autonics.net

#### ■ HEAD QUARTER

41-5, Yongdang-ri, Ungsang-eup, Yangsan-si Gyeongnam, Korea 626-847

- INTERNATIONAL SALES: 512 Ansung B/D, 410-13, Shindorim-dong, Guro-gu, Seoul, Korea 152-070
- TEL:82-2-2679-6585 / FAX:82-2-2679-6556 ■ E-mail: sales@autonics.net

NO20030117-EP-KE-03-0070B